



CE

09

EN 858-1

Fulfilled requirements of flow rate test according to standard EN858 (LGA)

h = Connection height from ground surface
mm (900...2500 mm)

Safety in case of fire: E
VTT test report VTT-S-7683-06

| | | | |
|----|-----------------------------------------------------------|------------------------------|-----------------------|
| B | Effective volume | 600 l | |
| A | Oil storage volume (height 150 mm) | 150 l | |
| 10 | ACCESSORY: Labcom -data transfer unit (x) | <input type="checkbox"/> | |
| 9 | OilSET-1000 oil alarm unit | | 1 |
| 9a | SET/DM3 -probe | | 1 |
| 8 | ACCESSORY: Floating adjustable cover Ø600, Standard EN124 | | |
| | Cover class A15 1.5 tn (x) | <input type="checkbox"/> | Part no. 3322 050 |
| | Cover class C250 25 tn | <input type="checkbox"/> | Part no. 3322 054 |
| | Cover class D400 40 tn | <input type="checkbox"/> | Part no. 3322 056 |
| | Frame | <input type="checkbox"/> | Part no. 3325 010 |
| 7 | EuroHUK 600 maintenance shaft (as needed), PE-MD | | 1 |
| | h = connection height from ground surface (mm) | | |
| | EuroHUK 600 h = 9-13 (x) | <input type="checkbox"/> | h = 900... 1300 mm |
| | EuroHUK 600 h = 13-17 | <input type="checkbox"/> | h = 1300... 1700 mm |
| | EuroHUK 600 h = 17-21 | <input type="checkbox"/> | h = 1700... 2100 mm |
| | EuroHUK 600 h = 21-25 | <input type="checkbox"/> | h = 2100... 2500 mm |
| 6 | Ventilation outlet (as needed) | PE | D110 |
| 5 | ACCESSORY: Automatic closure device | (x) <input type="checkbox"/> | 1 |
| 4 | Coalescer | | 2 |
| 3 | Outlet sewer | PE-HD | D160 |
| 2 | Inlet sewer | PE-HD | D160 |
| 1 | Tank (pH3-10/Heat resistance max. 50 °C) | PE-MD | 1300x1200 mm |

Product: EuroPEK Roo NS6 oil separator (I-class)

Drawing type: CUSTOMER DRAWING

Design by: TP/RJ Approved by: 13.4.2011 JP

Date: 13.4.2011

Scale 1:30

Construction site:



wavin
Labko

VAIVIN-LABKO Ltd.
Labkoite 1
FIN-36240 KANGASALA
FINLAND
Puh. +358 020 1285 200
Fax. +358 020 1285 280

Construction site:

Date: 13.4.2011

Scale 1:30

This drawing and the technical information included in the drawing are property of Wavin-Labko Ltd. Authorities' regulations must be known before providing the product. Products must be installed according to installation instructions.